

ADDENDUM NO. 11

June 14, 2022

REQUEST FOR PROPOSALS (PROPOSAL DOCUMENTS)

FOR

**SCHOOL OF BUSINESS BUILDING
PROJECT NO. 950592**



The following changes, additions, or deletions shall be made to the following documents as indicated for this Project; and all other terms and conditions shall remain the same. Each Proposer (Design Builder) is responsible for transmitting this information to all affected subcontractors and suppliers before the Proposal Deadline.

1. **DESIGN BUILDER QUESTIONS & ANSWERS**

Q176	The UCR provided documentation for the Biocontrol building includes only plan dimension for the coldroom/walk-in cooler. Please provide the required clear height inside the unit, and any interior shelving requirements.
A176	The clear height inside the unit is currently 8’- 9” and any interior shelving may be moved to the new facility. Any new interior shelving shall be consistent with the existing spaces while ensuring compliance with all applicable code requirements. At a minimum, please match quantity & storage capacity of existing casework/shelving (at the interior sink and cold room) to maintain current use.

END OF ADDENDUM